

875—93.8(89) Blowoff. Miniature boilers shall be equipped with a blowoff connection, not less than ½-inch pipe size, located to drain from the lowest water space practicable. The blowoff shall be equipped with a valve or cock not less than ½-inch pipe size.